



NOTES:

- 1) COMPLETE METER POLE INSTALLED BY CUSTOMER, EXCEPT FOR SLEMCO SERVICE CABLE.
- 2) METER BASE FURNISHED AND INSTALLED BY CUSTOMER.
- 3) FOR PERMANENT SERVICE, SERVICE CONDUIT IS PAID FOR OR PROVIDED BY CUSTOMER.
- 4) SERVICE CABLE FURNISHED AND INSTALLED BY SLEMCO AND PAID FOR BY CUSTOMER.
- 5) WIRING FROM METER BASE TO SERVICE DISCONNECT INSTALLED BY CUSTOMER. CUSTOMER WIRING AND DISCONNECT SHALL BE SIZED ACCORDING TO THE NATIONAL ELECTRICAL CODE (N.E.C.) OR GOVERNING AUTHORITY. CUSTOMER NEUTRAL MUST BE MARKED WITH WHITE OR NEUTRAL GRAY TAPE AT ALL POINTS OF CONNECTION.
- 6) VARIATIONS OF THIS DESIGN WILL BE CONSIDERED EQUAL, PROVIDED THE VARIATIONS MEET N.E.C. REQUIREMENTS.
- 7) THIS DESIGN MAY BE USED AS A TEMPORARY METER POLE FOR TEMPORARY SERVICE. IF USED AS A TEMPORARY METER POLE, THE CUSTOMER WILL SUPPLY THE SERVICE CONDUCTORS LONG ENOUGH TO REACH THE SLEMCO SERVICE CONNECTION POINT.
- 8) INSPECTION: IF A GOVERNING AUTHORITY REQUIRES INSPECTION, INSPECTION TAG MUST BE IN PLACE AND MARKED APPROVED BEFORE SLEMCO WILL CONNECT SERVICE.



UNDERGROUND METER POLE SPECIFICATION

REVISION 10/21/99