


NOTE: APPLICABLE TO BOTH RESIDENTIAL AND COMMERCIAL SERVICES.

RESIDENTIAL
SEE "SLEMCO - SPECIFICATIONS FOR RESIDENTIAL UNDERGROUND SECONDARY REQUIREMENTS" FOR MORE INFORMATION.

COMMERCIAL
SEE "SLEMCO - SPECIFICATIONS FOR COMMERCIAL UNDERGROUND SECONDARY REQUIREMENTS" FOR MORE INFORMATION.

CONDUIT SHOULD BE EVEN WITH NEUTRAL OR EVEN WITH BOTTOM OF TRANSFORMER

	SOUTHWEST LOUISIANA ELECTRIC MEMBERSHIP CORPORATION LOUISIANA 9 LAFAYETTE					
	SINGLE-PHASE UNDERGROUND SERVICE REQUIREMENTS FROM AN OVERHEAD SOURCE					
DRAWN BY:		CREATED ON: 01/15/97		SCALE: N.T.S.		
REVISIONS		REVISED BY	DATE	REV.	DRAWING NO.	REV.
SPLIT UNDERGROUND/OVERHEAD DRAWINGS		L. A. M.	09/05/99	2	4	4
		J. C. D.	03/01/11	3		
ENHANCEMENT TO DRAWINGS & SPECIFICATIONS		L. MECHE	04/21/16	4		
MADE APPLICABLE TO RESIDENTIAL AND COMMERCIAL		H. H. H	03/29/19	5		

SLEMCO ELECTRICAL STANDARDS		
APPROVED:	DATE:	PAGE NUMBER:
		14