

Engineering Service Specifications

Table of Contents

Commercial Service Requirements - Cross Reference Table	CSR-CRT1-11
 <u>Commercial Service Requirements</u>	
SLEMCO Commercial Service Order Procedure	38
Applicability of SLEMCO's Commercial Service Entrance Requirements	39
 <u>Commercial Transformer Foundation Details</u>	
Three-Phase Padmount Transformer Foundation - <i>Drawing No. 14</i>	40
Transformer Foundations Dimensions Table	41
 <u>Commercial Underground Primary Requirements</u>	
Specifications for Commercial Underground Primary Requirements	42
 <u>Commercial Three-Phase Current Transformer Metering Schemes</u>	
Specifications for Commercial Underground Current Transformer Metering Requirements for a Single Three-Phase Customer served from a New Underground Padmount Transformer	45
Three-Phase Current Transformer Metering Requirements from a new Padmount Transformer for a Single Customer - <i>Drawing No. 15</i>	49
Specifications for Commercial Underground Current Transformer Metering Requirements for Three-Phase Customers served from a New Underground Padmount Transformer	50
Three-Phase Current Transformer Metering Requirements from a new Padmount Transformer - <i>Drawing No. 16</i>	54
Specifications for Commercial Underground Current Transformer Metering Requirements for Three-Phase Customers served from an Existing Underground Padmount Transformer	55
Three-Phase Current Transformer Metering Requirements from an existing Padmount Transformer - <i>Drawing No. 17</i>	59
Specifications for Commercial Underground Current Transformer Metering Requirements for a Three-Phase Customer served from an Overhead Transformer Bank	60
Three-Phase Current Transformer Metering Requirements from an Overhead Source - <i>Drawing No. 18</i>	64
Specifications for Commercial Overhead Current Transformer Metering Requirements.....	65
Three-Phase Overhead Current Transformer Metering Requirements - <i>Drawing No. 19</i>	69
 <u>Commercial Single-Phase Current Transformer Metering Schemes</u>	
Specifications for Commercial Underground CT Metering Requirements for a Single-Phase Customer	70
Single-Phase CT Metering Requirements from an Existing Padmount Transformer - <i>Drawing No. 9</i>	74
Single-Phase CT Metering Requirements from a New Padmount Transformer - <i>Drawing No. 10</i>	75
Single-Phase CT Metering Requirements from an Overhead Source - <i>Drawing No. 11</i>	76
Specifications for Commercial Overhead CT Metering Requirements for a Single-Phase Customer	77
Single-Phase Overhead CT Metering Requirements - <i>Drawing No. 12</i>	80
 <u>Commercial Three-Phase Metering Schemes (self-contained meter base / no CTs)</u>	
Specifications for Commercial Underground Secondary Requirements for Three-Phase Customers	81
Three-Phase Underground Service Requirements from a New Padmount Transformer - <i>Drawing No. 20</i>	84
Three -Phase Underground Service Requirements from an Existing Padmount Transformer - <i>Drawing No. 21</i>	85
Three-Phase Underground Service Requirements from an Overhead Source - <i>Drawing No. 22</i>	86
Specifications for Commercial Overhead Service Requirements	87
Three-Phase Overhead Service Requirements - <i>Drawing No. 23</i>	89

Engineering Service Specifications
Table of Contents (Cont'd)

Commercial Single-Phase Metering Schemes (self-contained meter base / no CTs)

Specifications for Commercial Underground Secondary Requirements90
Single-Phase Underground Service Requirements from an Existing Padmount Transformer - *Drawing No.2*93
Single-Phase Underground Service Requirements from a New Padmount Transformer - *Drawing No.3*.....94
Single-Phase Underground Service Requirements from an Overhead Source - *Drawing No.4*.....95

Commercial Service Requirements for Multiple Occupancy Buildings

Specifications for Commercial Metering Requirements for Three-Phase Customers within
Multiple Occupancy Building served from a New Underground Padmount Transformer.....96
Sample Configuration of Customers within a Multiple Occupancy Building served from
3-Phase Padmount Transformer - *Drawing No.24* 101

Specifications for Commercial Metering Requirements for Single-Phase Customers within
Multiple Occupancy Building served from a New Underground Padmount Transformer..... 102
Sample Configuration of Customers within a Multiple Occupancy Building served from
1-Phase Padmount Transformer - *Drawing No.25* 108